



**ADDENDUM NO. 1**

**BID NO. 2023-011**

**Wednesday, April 26, 2023**

**TO ALL BIDDERS:**

Please incorporate the following information/clarifications, changes, additions, and/or deletions into the specification packet for the above-referenced project:

**CLARIFICATION:**

1. In reference to the Electrical Plans (Sheet E-07), a 25G tower is an acceptable alternative to the plan specified 45G tower. Wind load calculations exemplifying that the alternative meets applicable State/City standards will need to be provided for review and subsequent approval prior to material purchasing.

*Kelly McGilvray*

Kelly McGilvray  
Buyer II

Wednesday, April 26, 2023

Please sign and return the acknowledgment page of this addendum by email or by fax. The original acknowledgement page is to be included with your qualifications submission.

## ACKNOWLEDGEMENT FORM

### ADDENDUM NO. 1

### BID NO. 2023-011

I acknowledge receipt of Addendum No. 1 for BID No. 2023-011. This addendum contains two (2) pages. Please include the original of this form in your qualifications submission.

Company Name: \_\_\_\_\_

Address: \_\_\_\_\_

Name of Signer \_\_\_\_\_  
(please print)

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

Telephone: \_\_\_\_\_ Facsimile: \_\_\_\_\_

Please fax your completed form to (954) 935-5258 or e-mail to [purchase@margatefl.com](mailto:purchase@margatefl.com).

*Kelly McGilvray*  
Kelly McGilvray  
Buyer II

Wednesday, April 26, 2023

NOTE: The original of this form must be included with your qualifications submission.