



## **ADDENDUM NO. 1**

### **BID NO. 2022-007 FURNISH AND INSTALL (8) HVAC SYSTEMS**

July 25, 2022

#### **TO ALL BIDDERS:**

Please incorporate the following information/clarifications, changes, additions, and/or deletions into the TECHNICAL SPECIFICATIONS of the bid packet for the above referenced project:

#### **QUESTIONS AND CLARIFICATIONS:**

1. The new units and the existing curb adapters all have the same footprints. Therefore if you elect to change them we will be installing the same curbs that is currently installed. Please advise given that piece of information would you still want all the adapters to be changed because most of them are all in good shape with the exception of the 10-ton located at the senior center?

**Answer: The curbs sizes are not expected to change.**

2. The 7.5-ton on RTU on City Hall has a smoke detector that is not wired into the unit or the fire alarm. Therefore we are unable to know if this is a working smoke detector or if it needs replacing. Please advise if this is something that the City would take care of thru Bass the fire monitoring company before the final inspection?

**Answer: The City will take care of it.**

3. Please advise given the dates and times of operation of Calypso Cove water park. What would be the plan for a schedule to install the units at this facility?

**Answer: Monday to Thursday 8:00 am – 4:00 pm**

4. Can you please advise what is the budget for the bid Furnish and Install (8) HVAC Systems?

Answer: The budget amount is \$100,000.00.

**NOTE: THE BID DUE DATE/TIME HAS CHANGED FROM 11:00 AM ON WEDNESDAY, AUGUST 3<sup>RD</sup>, 2022 TO 2:00 PM, WEDNESDAY, AUGUST 3<sup>RD</sup>, 2022.**

**PLEASE UPDATE ALL REFERENCES TO THE BID DUE DATE/TIME IN YOUR BID DOCUMENTS TO THE DATE/TIME INDICATED ABOVE.**

This addendum consists of three (3) pages.

There are no other changes at this time.

**Nirmala Samlal**

Nirmala Samlal

Buyer I

7/25/2022

Please sign and return the acknowledgment page of this addendum by email or by fax. The original acknowledgement page is to be included with your qualifications submission.

## ACKNOWLEDGEMENT FORM

### ADDENDUM NO. 1

#### BID NO. 2022-007 FURNISH AND INSTALL (8) HVAC SYSTEMS

I acknowledge receipt of Addendum No. 1 for BID No. 2022-007, Furnish and Install (8) HVAC Systems. This addendum contains three (3) pages. Please include the original of this form in your qualifications submission.

Company Name: \_\_\_\_\_

Address: \_\_\_\_\_

Name of  
Signer \_\_\_\_\_  
(please print)

Signature: \_\_\_\_\_

Date: \_\_\_\_\_

Telephone: \_\_\_\_\_

Facsimile: \_\_\_\_\_

Please fax your completed form to (954) 935-5258 or e-mail to [purchase@margatefl.com](mailto:purchase@margatefl.com).

**Nirmala Samlal** \_\_\_\_\_

Nirmala Samlal

Buyer I

7/25/2022

NOTE: The original of this form must be included with your qualifications submission.