



# City of Margate

5790 Margate Boulevard  
Margate, FL 33063  
954-972-6454  
www.margatefl.com

## Legislation Text

---

**File #:** ID 2017-006, **Version:** 1

---

**TO:** Planning and Zoning Board

**FROM:** Benjamin J. Ziskal, AICP, CEcD, Director of Economic Development

**DATE:** February 7, 2017

**PZ-03-17** CONSIDERATION OF AN ORDINANCE AMENDING CHAPTER 14 FIRE HYDRANTS AND DELETING SECTION 39.4.1 ENFORCEMENT OF FIRE HYDRANT REQUIREMENTS OF THE CODE OF ORDINANCES  
**PETITIONER:** CITY OF MARGATE, DEPARTMENT OF ENVIRONMENTAL AND ENGINEERING

**BACKGROUND:** The proposed amendments clarify, simplify, consolidate, and update the City's fire hydrant requirements. A summary of the proposed changes are as follows:

- Adds term definitions
- Consolidates and simplifies the hydrant spacing requirements
- Reduces minimum water main sizes to come in line with common municipal standards (fire flow rates remain the same)
- Removes obsolete zoning designations, terms, and product numbers
- Deletes metric units
- Moves enforcement language from Chapter 39 to Chapter 14 for consolidation purposes

**RECOMMENDATION:** This item was approved by the Development Review Committee (DRC) on January 10, 2017. A draft copy of the minutes from the January 10, 2017 DRC meeting is attached.

**FISCAL IMPACT:** N/A

**CONTACT PERSON:** Benjamin J. Ziskal, AICP, Director of Economic Development