



City of Margate

5790 Margate Boulevard
Margate, FL 33063
954-972-6454
www.margatefl.com

Legislation Text

File #: ID 2017-092, **Version:** 1

TO: Mayor and City Commission

FROM: Douglas E. Smith, City Manager

DATE: March 1, 2017

APPROVAL OF AN ORDINANCE AMENDING CHAPTER 14 FIRE HYDRANTS AND DELETING SECTION 39.4.1 ENFORCEMENT OF FIRE HYDRANT REQUIREMENTS OF THE CODE OF ORDINANCES.

BACKGROUND: The proposed amendments clarify, simplify, consolidate, and update the City's fire hydrant requirements. A summary of the proposed changes are as follows:

- Adds term definitions
- Consolidates and simplifies the hydrant spacing requirements
- Reduces minimum water main sizes to come in line with common municipal standards (fire flow rates remain the same)
- Removes obsolete zoning designations, terms, and product numbers
- Deletes metric units
- Moves enforcement language from Chapter 39 to Chapter 14 for consolidation purposes

RECOMMENDATION: This item was before the Development Review Committee (DRC) on January 10, 2017. A copy of the minutes from the January 10, 2017 DRC meeting is attached. The proposed ordinance was approved by the Planning and Zoning Board on February 7, 2017 with a 3-0 vote. A draft copy of the minutes from the Planning and Zoning Board meeting is also attached.

FISCAL IMPACT: N/A

CONTACT PERSON: Benjamin J. Ziskal, AICP, Director of Economic Development